

FIRE-RESISTIVE BARRIERS

- Fire doors and fire dampers maintained to be fully operational
- Fire-resistive walls and ceilings maintained without holes, breaks, or missing panels

FLAMMABLE LIQUIDS

- Orlando Fire Dept. restrictions regarding flammable liquids continually observed

HAZARDOUS MATERIALS

- Orlando Fire Dept. renew annually Hazardous Materials Inventory Statement with quantity stored and quantity in regular use

FIRE HYDRANTS (PRIVATE OWNED)

- Fire hydrants serviced, tagged and painted annually by licensed company. Send report to the Orlando Fire Dept. 78 W. Central Blvd., Orlando, FL 32801 attention Hydrant Coordinator.



FIRE SAFETY CHECKLIST



Make fire prevention a high priority for your business. Always be on the look-out for fire hazards and make sure you have the proper fire safety equipment.

**407.246.2390 • CITYOFORLANDO.NET/FIRE
PO BOX 2846, ORLANDO, FL 32802-4990**

EXITS

- Exit corridors and aisles remain unobstructed, free of any material or matter at all times
- Exit doors are able to be opened from inside without a key, special knowledge, or effort
- Main entry door, ONLY, may have deadbolt lock but is unlocked during business hours, without fail
- Exit signs in place to clearly indicate exit path, minimum 6-inch letters with 3/4-inch stroke
- Exit signs are illuminated when building is occupied

FIRE EXTINGUISHERS AND FIRE PROTECTION SYSTEMS

- Fire extinguishers serviced annually by State Fire Marshal-licensed company as well as if discharged or if tampered with
- Extinguishers have minimum rating of 2A:10B:C and are located at an exit or on an exit path every 75 feet of travel or as otherwise required by the Fire Department
- Extinguishers mounted 3-1/2 to 5 feet above floor
- Fire Protection systems shall be tagged quarterly and annually by State Fire Marshal-licensed company

ELECTRICAL

- No extension cords or multi-plug adapters in use
- No electrical cords extending through walls, ceilings, floors, under doors, or floor covering
- No damaged electrical cords, plugs, or outlets
- 30-inch minimum clearance maintained around circuit panel

GENERAL FIRE SAFETY

- Combustible storage maintained at least 24 inches below ceiling (18 inches if sprinklered)
- No combustibles stored in furnace or electrical rooms or below stairs
- Clearance maintained between heat-producing equipment and combustibles
- Storage maintained in neat and orderly manner to minimize fire spread and facilitate control
- Dumpsters are a minimum of 5 feet from combustibles; covers kept closed
- Compressed gas cylinders are properly secured and contents clearly labeled.