



COMMERCIAL HOOD

(Second Rough-in) Inspection

- Hood and exhaust duct properly protected from combustible construction.
- Shaft is constructed and clearance to shaft wall inspection complete or alternate materials for shaft installed with installation instructions on jobsite for inspection if required.
- All clearances must meet N.F.P.A. 96 and FMC 2004.
- Approved plans on site for inspection.

This document is intended to be a guide and may not contain all requirements needed to obtain permits and approval from the City of Orlando.