



### **COMMERCIAL HOOD ROUGH-IN INSPECTION**

(2004 Florida Mechanical Code, N.F.P.A. 1996)

- All make-up air and exhaust duct(s) are installed.
- Exhaust duct light tested for holes (minimum 150 watt bulb).
- Approved plans on site for inspection.

**This document is intended to be a guide and may not contain all requirements needed to obtain permits and approval from the City of Orlando.**